

E4 Compliance Checklist

The installed Ecoglo signs comply with NCC Part E4 because:

Ecoglo S20 Signs comply with NCC specification E4.8 when there is at least 100 lux on the face of the sign from a continuous dedicated light source with a colour temperature of 4000K or greater.

OR

Ecoglo S20 Signs comply with NCC Part EP4.2 when used as a part of a Performance Solution which ensures that the sign is visible for sufficient time to allow safe evacuation.

Note: Ecoglo Hybrid Exit Signs are compliant with E4.8 - see Hybrid Sign Compliance Guide (available for download from TECHNICAL section at www.ecoglo.com.au)

Product luminance reports, data sheets, installation instructions, and Ecoglo's recommended maintenance/checking procedures can be found on the Ecoglo website: www.ecoglo.com.au under the 'PRODUCT' and 'TECHNICAL' sections.



VISIBLY BETTER

Ecoglo Australia

Phone: +61 3 8691 5288

www.ecoglo.com.au

Email: info@ecoglo.com