

# Maintenance Checking

Recommended Maintenance Checking Procedure for Ecoglo S20 signs:

## 6 Monthly Maintenance Check

COMPLETED 

- There has been no change to the configuration of the building which renders the marked escape routes unusable.
- All signs are still configured as at installation and there is no material damage to any of the signs.
- All signs are clean from general dust build up and any other specific obscuring deposits.
- All signs are clearly visible and have not been covered up.
- All dedicated light sources checked that the positions have not altered from design.
- All dedicated light sources are in working order and clean.
- All automated lighting control systems are operational as per design.

*For more detailed information re inspection and maintenance procedures see PLCS 101 Photoluminescent Exit Signs Standard, Part C - Inspection and Maintenance (available for download from the Homepage at [www.plcouncil.com.au](http://www.plcouncil.com.au))*

  
VISIBLY BETTER

**Ecoglo Australia**

Phone: +61 3 8691 5288

Email: [info@ecoglo.com](mailto:info@ecoglo.com)

[www.ecoglo.com.au](http://www.ecoglo.com.au)